

Permit Application for Liquefied Petroleum Gases in Above Ground Storage Tanks



Davenport Fire Department

331 Scott Street

Davenport, Iowa 52801

Read the following and place an "X", on the line, to signify that you understand the requirements. If you do not understand, or do not agree to follow the requirements, do not place an "X", on the line.

A \$125 permit fee is required, for the tank installation, and an additional \$25 for each dispenser, prior to issuing the permit.

Payment: Check shall be made payable to: The City of Davenport Fire Department.

Mail permit application and payment to: Davenport Fire Department, Fire Marshall's Office, 331 Scott Street, Davenport, Iowa 52801.

Business Name_____ Address_____

Above Ground Storage Tank Requirements

- _____ 1. Above Ground Storage LP Tank installations shall comply with the International Fire Code (2012), the National Fire Protection Association Standards, International Fuel Gas Code, and required Federal, State, and Local requirements.
- _____ 2. A permit must be issued by the Davenport Fire Department's Fire Marshal's Office, before any work can be started, on the site.
- _____ 3. The permit applicant shall provide a completed permit application, a legible and drawn to scale site diagram, business name, business address, amount and type of materials to be stored, tank distance from nearby streets, buildings, and property lines. The plans shall be submitted, with the completed permit application.

Permit Application for Liquefied Petroleum Gases

in Above Ground Storage Tanks

- _____ 4. The design, fabrication, and installation, of above ground LP storage tanks, shall comply with IFC Chapter 61, NFPA 58, and the International Fuel Gas Code.

Electrical Requirements

- _____ 5. The electrical wiring and equipment shall comply with the IFC Chapter 61, NFPA 58, the International Fuel Gas Code, and the requirements of the City of Davenport, Building Department.

Piping/Venting Requirements

- _____ 6. The design, fabrication, and installation of piping system components shall comply with IFC Chapter 61, the International Fuel Gas Code, and NFPA 58.

Fire Protection Requirements

- _____ 7. Fire protection systems shall be required, and installed, according to IFC Chapter 61 and NFPA 58. The Fire Marshal's Office has the authority to require additional safeguards, where he/she deems necessary.

Vehicle Protection Requirements

- _____ 8. Vehicle impact protection shall be required, according to IFC Chapter 61 and NFPA 58.

Hazard Identification Signs

- _____ 9. Visible hazard identification signs must be placed on the container and/or at the entrances to locations, where the hazardous material is stored. The signs shall meet NFPA 704.

Sources of Ignition

- _____ 10. Sources of ignition shall comply with IFC Chapter 61 and NFPA 58.

Dispensing of LP

- _____ 11. Dispensing of liquefied petroleum gas shall comply with IFC Chapter 61 and NFPA 58.

Permit Application for Liquefied Petroleum Gases in Above Ground Storage Tanks

The business or property owner, where the tank will be installed, agrees and understands to meet the above requirements, as identified in the codes.

Failure to comply with these requirements will result in denial or revocation of the permit, by the Authority Having Jurisdiction.

Signature of Applicant_____

Date_____